

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AE0021**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### 1328-A01 Dorgard / Dorgard SmartSound / Dorgard Pro Door Holders (Size 3 to 7)

**Intended use:** For use on fire single leaf and double leaf doors  
**STANDARD FIXING APPLICATION**

Essential Characteristics	Performance	Harmonised Technical Specification
<b>Mechanical Test Evidence:</b> WIL WIL 165682, WIL 380799 & WIL 541244 <b>Fire Test Evidence:</b> WF 388360 AR Iss 4, Chilt/RF07048, WF 198001, WF 375225 & WF 388720		
Ability to release		EN1155:1997+A1:2002/AC:2006
5.1.2 release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	Pass	
5.1.5 External electrical connection	Pass	
5.1.6 Inlet for external wiring	Pass	
5.2.1 General	Pass	
5.2.2 Electrical release requirements	Pass	
5.2.3 Door closing device requirements	NPD	
5.2.4 Durability	Pass	
5.2.5 Angle of hold open	Pass > 65°	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	Pass	EN1155:1997+A1:2002/AC:2006
5.2.9 Delayed release	NPD	
5.2.10 Electrical performance	Pass	
5.2.11 Temperature Rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire / smoke doors	Grade 1	
Durability of Ability to release		
5.2.4 Durability	50,000 Test Cycles	
5.2.14.1 corrosion	NPD	
5.2.14.2 corrosion	NPD	
Dangerous Substances Annex ZA3	Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	EN1155:1997+A1:2002/AC:2006

Notified Body No. 2812

## Certificate of Constancy of Performance

**2812-CPR-AE0021**

Placed on the Market under the Name of

**FIRECO LIMITED  
Grange Road  
Southwick  
Brighton  
BN42 4DQ  
United Kingdom**

and produced in the manufacturing plant

**CEP36593-2**

**This is coded format and the information is held by the Notified Body**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 1155:1997+A1:2002/AC:2006**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **21/04/2022** and re-issued on **10/03/2025** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **19/04/2028**

ERO Project Reference: **034621 P2584**



Pascal Coget  
General Manager – European Certification

CSF408-NL 8.0