

Approved body No. 1121

## Certificate of constancy of performance

**1121-CPR-UK- AE7839**

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

### **1328-A01 Dorgard / Dorgard SmartSound / Dorgard Pro Door Holders (Size 3 to 7)**

Intended use:-

For use on fire rated single leaf and double leaf doors  
**STANDARD FIXING APPLICATION**

Essential characteristics	Performance	Designated Standard
<b>Mechanical Test Evidence: WIL WIL 165682, WIL 380799 &amp; WIL 541244</b> <b>Fire Test Evidence: WF 388360 AR Iss 4, Chilt/RF07048, WF 198001, WF 375225 &amp; WF 388720</b>		
Ability to release		EN1155:1997+A1:2002/AC:2006
5.1.2 release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	Pass	
5.1.5 External electrical connection	Pass	
5.1.6 Inlet for external wiring	Pass	
5.2.1 General	Pass	
5.2.2 Electrical release requirements	Pass	
5.2.3 Door closing device requirements	NPD	
5.2.4 Durability	Pass	
5.2.5 Angle of hold open	Pass > 65°	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	Pass	
5.2.9 Delayed release	NPD	
5.2.10 Electrical performance	Pass	
5.2.11 Temperature Rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire / smoke doors	Grade 1	
<b>Essential characteristics</b>	<b>Performance</b>	<b>Designated Standard</b>
Durability of Ability to release		EN1155:1997+A1:2002/AC:2006
5.2.4 Durability	50,000 Test Cycles	
5.2.14.1 corrosion	NPD	
5.2.14.2 corrosion	NPD	
Dangerous Substances Annex ZA3	Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

Approved body No. 1121

## Certificate of constancy of performance

1121-CPR-UK- AE7839

Placed on the market under the name of

**FIRECO LIMITED  
GRANGE ROAD  
SOUTHWICK  
BRIGHTON  
BN42 4DQ  
UNITED KINGDOM**

and produced in the manufacturing plant

**CEP36593-2**

**This is coded format and the information is held by the Approved Body**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 1155:1997+A1:2002/AC:2006**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **26/05/2022** and re-issued on **24/01/2025** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **25/05/2028**



0087

A handwritten signature in black ink, appearing to read 'Paul Duggan'.

**Paul Duggan  
Certification Manager**

**Warringtonfire Testing and Certification Limited  
Unit 722, The Quadrant, Birchwood Park, Warrington, WA3 6FW, UK**