



CERTIFICATE OF APPROVAL
No CF 611

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

EUROSPEC ARCHITECTURAL HARDWARE LIMITED

Stancliffe Street, Mill Hill, Blackburn BB2 2QR
Tel: 01254 274100 Fax: 01254 274111

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

*Eurospec Locks and
Latches*

TECHNICAL SCHEDULE

**TS23 The Contribution of Locks
and Latches to the Performance
of Fire Resisting of Doorsets**

Signed and sealed for and on behalf of CERTIFIRE

Sir Ken Knight
Chairman - Management Council

Issued: 6th May 2009
Valid to: 5th May 2014

Page 1 of 6



Only valid when authentic
CERTIFIRE Seal is in place



CERTIFICATE No CF 611

EUROSPEC ARCHITECTURAL HARDWARE LIMITED

Eurospec Locks and Latches

1. This approval applies only to the Eurospec locks and latches detailed later in this certificate.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section D of the Technical Standards (Scotland) and Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
3. This approval relates to their use with the following door assemblies: -

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 60 minutes (Code ITT).
4. The locks and latches are approved on the basis of:
 - i) Initial type testing to EN12209 and BS EN 1634-1: 2000
 - ii) An appraisal against TS23
 - iv) Certification of quality management system to ISO 9001: 2008.
 - v) Inspection and surveillance of factory production control
 - v) Ongoing audit testing in accordance with TS23 requirements
5. This approval is applicable only to the specified locks/latches used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and, when fitted to timber based doorsets, using appropriate intumescent protection. The required protection will be i2 mm thick Mono Ammonium Phosphate intumescent sheet behind the forend and strike/keep plates and around the lock case for all doorset assemblies. Failure to install the protection will invalidate this certificate. It is also required that 60 minute doorsets incorporate 4 mm thick, non-combustible, mineral based sub-facings.
6. Lock assemblies not incorporating a latching mechanism or incorporating a rollerbolt latching mechanism shall only be fitted to proven unlatched doorset assemblies.
7. The approval relates to on going production. Product and/or its immediate packaging are identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
8. The locks/latches should not be fitted higher than 1100 mm from the finished floor level of the surrounding floors.



CERTIFICATE No CF 611
EUROSPEC ARCHITECTURAL HARDWARE LIMITED

Eurospec Locks and Latches

9. The doorset shall be installed in accordance with BS 8214: 2008.
10. The following table shows acceptable doorset types and fire resistance periods:

Approved Door Type							
Class	IMM	MM	TT	ITT	ITM	ITC	TM
FD20	x	x	x	✓	x	x	x
FD30	x	x	x	✓	x	x	x
FD60	x	x	x	✓	x	x	x
FD120	x	x	x	x	x	x	x
FD240	x	x	x	x	x	x	x
E 20	x	x	x	✓	x	x	x
EI 20	x	x	x	✓	x	x	x
E 30	x	x	x	✓	x	x	x
EI 30	x	x	x	✓	x	x	x
E 60	x	x	x	✓	x	x	x
EI 60	x	x	x	✓	x	x	x
E 90	x	x	x	x	x	x	x
EI 90	x	x	x	x	x	x	x
E 120	x	x	x	x	x	x	x
EI 120	x	x	x	x	x	x	x
E 240	x	x	x	x	x	x	x
EI 240	x	x	x	x	x	x	x

See CERTIFIRE Technical Schedules for designation of doorset types i.e. ITT etc.



CERTIFICATE No CF 611
EUROSPEC ARCHITECTURAL HARDWARE LIMITED

Eurospec Locks and Latches

Approved lock/latch models and classifications.

Lock/Latch Reference	Description	Classification to EN 12209: 2003										
LSB5525	BS 5 LEVER SASHLOCK	2	H	8	1	0	F	7	K	D	2	B
LSB5530	BS 5 LEVER SASHLOCK											
LDB5525	BS 5 LEVER DEADLOCK	2	H	8	1	0	F	7	K	D	0	B
LDB5530	BS 5 LEVER DEADLOCK											
ESB5025	BS EURO PROFILE SASHLOCK	2	H	8	1	0	F	7	B	A	2	0
ESB5030	BS EURO PROFILE SASHLOCK											
EDB5025	BS EURO PROFILE DEADLOCK	2	H	8	1	0	F	7	B	A	0	0
EDB5030	BS EURO PROFILE DEADLOCK											
DLS7260EP	DIN SASHLOCK	3	M	8	1	0	F	3	B	A	2	0
DLS7260NL	DIN NIGHTLATCH											
DLE7255NL	DIN NIGHTLATCH	3	M	8	1	0	F	-	B	0	2	0
DLE0055L	DIN LATCH											
DLS0060L	DIN LATCH	3	M	8	1	0	F	3	B	A	0	0
DLS0060EP	DIN DEADLOCK											
DLS7860WC	DIN BATHROOM LOCK	3	M	8	1	0	F	-	B	G	2	0
DLE7855WC	DIN BATHROOM LOCK											
LSS5325	3 LEVER SASHLOCK	2	H	8	1	0	F	2	K	D	2	A
LSS5330	3 LEVER SASHLOCK											
URLS5325	3 LEVER SASHLOCK											
URLS5330	3 LEVER SASHLOCK											
LSS5525	5 LEVER SASHLOCK	2	H	8	1	0	F	2	K	D	2	B
LSS5530	5 LEVER SASHLOCK											
URLS5525	5 LEVER SASHLOCK											
URLS5530	5 LEVER SASHLOCK											
LDS5325	3 LEVER DEADLOCK	3	H	8	1	0	F	2	K	D	0	A
LDS5330	3 LEVER DEADLOCK											
URLD5325	3 LEVER DEADLOCK											
URLD5330	3 LEVER DEADLOCK											
LDS5525	5 LEVER DEADLOCK	3	H	8	1	0	F	2	K	D	0	B
LDS5530	5 LEVER DEADLOCK											
URLD5525	5 LEVER DEADLOCK											
URLD5530	5 LEVER DEADLOCK											



CERTIFICATE No CF 611
EUROSPEC ARCHITECTURAL HARDWARE LIMITED

Eurospec Locks and Latches

Approved lock/latch models and classifications.

Lock/Latch Reference	Description	Classification to EN 12209: 2003																					
		2	H	8	1	0	F	2	B	A	2	0											
ESS5025	EURO PROFILE SASHLOCK	2	H	8	1	0	F	2	B	A	2	0											
ESS5030	EURO PROFILE SASHLOCK																						
OSS5025	OVAL PROFILE SASHLOCK																						
OSS5030	OVAL PROFILE SASHLOCK																						
EDS5025	EURO PROFILE DEADLOCK	3	H	8	1	0	F	2	B	A	0	0											
EDS5030	EURO PROFILE DEADLOCK																						
ODS5025	OVAL PROFILE DEADLOCK																						
ODS5030	OVAL PROFILE DEADLOCK																						
ULS5025	UPRIGHT LATCH	2	H	8	1	0	F	-	B	0	2	0											
ULS5030	UPRIGHT LATCH																						
FLL5025	ONE WAY BOX LATCH																						
FLL5030	ONE WAY BOX LATCH																						
BAS5025	BATHROOM LOCK	2	H	8	1	0	F	-	B	G	2	0											
BAS5030	BATHROOM LOCK																						
URBS5025	BATHROOM LOCK																						
URBS5030	BATHROOM LOCK																						
FLD8025	BATHROOM DEADLOCK	3	H	8	1	0	F	-	B	G	0	0											
FLD8030	BATHROOM DEADLOCK																						
FLD8040	BATHROOM DEADLOCK																						
TLD5025	BATHROOM DEADLOCK																						
TLD5030	BATHROOM DEADLOCK																						
TLD5040	BATHROOM DEADLOCK																						
TLD5825	BATHROOM DEADLOCK																						
TLD5830	BATHROOM DEADLOCK																						
TLD5840	BATHROOM DEADLOCK																						
DLE7255 EP	DIN SASHLOCK												3	M	8	1	0	F	3	B	C	2	0
DLE0055EP	DIN DEADLOCK												3	M	8	1	0	F	3	B	C	0	0
LSE5225	2 LEVER SASHLOCK												2	H	8	1	0	F	1	K	D	2	0
LSE5230	2 LEVER SASHLOCK																						
LSE5225REB	2 LEVER REBATED SASHLOCK																						
LSE5325	3 LEVER SASHLOCK	2	H	8	1	0	F	1	K	D	2	A											
LSE5330	3 LEVER SASHLOCK																						
LDE5325	3 LEVER DEADLOCK	2	H	8	1	0	F	1	K	D	0	A											
LDE5330	3 LEVER DEADLOCK																						
BAE5025	BATHROOM LOCK	2	H	8	1	0	F	-	B	G	2	0											
BAE5030	BATHROOM LOCK																						



CERTIFICATE No CF 611
EUROSPEC ARCHITECTURAL HARDWARE LIMITED

Eurospec Locks and Latches

Approved lock/latch models and classifications.

Lock/Latch Reference	Description	Classification to EN 12209: 2003										
		2	H	8	1	0	F	-	B	0	2	0
ULE5025	UPRIGHT LATCH	2	H	8	1	0	F	-	B	0	2	0
ULE5030	UPRIGHT LATCH											
RSE8053	RIM SASHLOCK	1	A	8	1	0	F	NPD	M	D	NPD	0
RSE8064	RIM SASHLOCK											
RLE8043	RIM LATCH	NPD	C	8	1	0	F	-	E	0	NPD	0
RDE8043	RIM DEADLOCK	1	C	8	1	0	F	NPD	M	D	0	0
TLS5025	ONE WAY TUBULAR LATCH	NPD	A	7	1	0	NPD	-	B	0	NPD	0
TLS5030	ONE WAY TUBULAR LATCH											
TLS5040	ONE WAY TUBULAR LATCH											
TLS5050	ONE WAY TUBULAR LATCH											
URES5025	EURO PROFILE SASHLOCK	2	H	8	1	0	F	1	B	A	2	0
URES5030	EURO PROFILE SASHLOCK											
UROS5025	OVAL PROFILE SASHLOCK											
UROS5030	OVAL PROFILE SASHLOCK											
URED5025	EURO PROFILE DEADLOCK	3	H	8	1	0	F	1	B	A	0	0
URED5030	EURO PROFILE DEADLOCK											
UROD5025	OVAL PROFILE DEADLOCK											
UROD5030	OVAL PROFILE DEADLOCK											
RSL5030	ROLLERBOLT DEADBOLT	3	C	8	1	0	F	2	B	A	0	0

Further Information

Further information regarding the details contained in this certificate may be obtained from Eurospec Architectural Hardware Limited (Tel: 01254 274100).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).