

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK- AE7873

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Type 80 - Agrippa Acoustic Fire Door Holder Size 5

Intended use: For use on fire rated single leaf and double leaf doors

STANDARD DOOR MOUNT PULL APPLICATION

Essential characteristics	Performance	Designated Standard
Mechanical Test Evidence: WIL 537571 Fire Test Evidence: WF 529491		
Ability to release 5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring 5.2.1 General 5.2.2 Electrical release requirements 5.2.3 Door closing device requirements 5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.2.11 Temperature Rise 5.2.12 Damage 5.2.13 Fire / smoke doors	Pass Pass 3.1V NPD – Battery Powered NPD – Battery Powered Pass Pass NPD Pass Pass > 65° Pass Pass Pass NPD Pass NPD Pass Grade 1	EN1155:1997+A1:2002/AC:2006
Essential characteristics	Performance	
Durability of Ability to release	50,000 Test Cycles	EN1155:1997+A1:2002/AC:2006
5.2.4 Durability		
5.2.14.1 corrosion		
5.2.14.2 corrosion	NPD	
Dangerous Substances Annex ZA3	Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

Approved Body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK- AE7873

Placed on the market under the name of

**Stephenson Gobin Ltd
20 Longfield Road
South Church Enterprise Park
Bishop Auckland
County Durham
DL14 6XB
United Kingdom**

and produced in the manufacturing plant:

E014007-1 & E014007-2

This is coded format, and the information is held by the Approved Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1155:1997+A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **01/08/2024** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **31/07/2027**



0087

A handwritten signature in black ink, appearing to read 'Paul Duggan'.

**Paul Duggan
Certification Manager**

**Warringtonfire Testing and Certification Limited
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK**